



# Bharat Quality Testing Lab

NABL Accredited /AN ISO 9001-2015 Certified

# 3738, 1st Main Road, Gayathrinagar  
Bangalore – 560021 Ph: 080299025094  
Mob.: 9071286611, 9035662508  
Email – bqtlab@gmail.com  
Website-www.bqtlab.com

## TEST REPORT

<b>Report No. :</b> BQTL/2024/82/3820	<b>Report Date :</b> 02.05.2024
<b>M/S.National Public School</b> #14/A, 15 <sup>th</sup> Main Rd, 9 <sup>th</sup> cross Sadashivanagar, Bangalore-560 080	<b>Customer Reference :</b> Verbal
	<b>Date of Receipt :</b> 30.04.2024
	<b>Date of test Start :</b> 30.04.2024
<b>Sample received by :</b> Customer	<b>Date of Completion of Test:</b> 02.05.2024
<b>Sample Nature :</b> Drinking Water	<b>Sample Job Number :</b> BQTL/2024/3820
	<b>Sample Particulars :</b> Water

Sample Description: Colourless Odorless Transparent Liquid.

### Physical & Chemical Test

Sl. No	Tests	Result	Limits as per IS 10500 : 2012 (Rev 2)		Protocol
			Maximum Acceptable Limits	Maximum Permissible Limits	
1	Colour, Hazen Units	<5	5	15	IS 3025/Part-4
2	Odour	Agreeable	Agreeable	Agreeable	IS 3025/Part-5
3	pH Value	7.38	6.5 – 8.5	No Relaxation	IS 3025/Part-11
4	Turbidity as NTU	<1	1	5	IS 3025/Part-10
5	Total Hardness as CaCO <sub>3</sub> , mg/L	204	200	600	IS 3025/Part-21
6	Calcium as Ca, mg/L	54.6	75	200	IS 3025/Part-40
7	Magnesium as Mg, mg/L	19.0	30	100	IS 3025/Part-46
8	Total Dissolved Solids, mg/L	480	500	2000	IS 3025/Part-16
9	Chloride as Cl, mg/L	47.2	250	1000	IS 3025/Part-32
10	Sulphate as SO <sub>4</sub> , mg/L	12.0	200	400	IS 3025/Part-24
11	Nitrate as NO <sub>3</sub> , mg/L	4.0	45	No Relaxation	IS 3025/Part-34
12	Iron as Fe, mg/L	0.18	0.3	1	IS 3025/Part-53
13	Fluoride as F, mg/L	0.43	1.0	1.5	IS 3025/Part-60
14	Zinc as Zn, mg/L	<0.1	5	15	IS 3025/Part-49
15	Chromium as Cr <sup>6+</sup>	<0.01	0.05	No Relaxation	IS 3025/Part-52
16	Copper as Cu, mg/L	<0.01	0.05	1.5	IS 3025/Part-42
17	Aluminium as Al, mg/L	<0.01	0.03	0.2	IS 3025/Part-55
18	Boron as B, mg/L	<0.1	0.5	1.0	IS 3025/Part-57
19	Manganese as Mn, mg/L	<0.1	0.1	0.3	IS 3025/Part-59
20	Total Alkalinity as CaCO <sub>3</sub> , mg/L	267	200	600	IS 3025/Part-23

### Microbiological Test

Tests	Results	Limits as Per IS 10500-2012	Protocol
Total Coliform/100ml	Absent	Not detectable	IS 1622

#### Remarks:

Chemical –Above tested sample meets to Permissible limits as per IS 10500: 2012, with respect to above parameters.

Microbiology–Tested Sample Conforms to IS 10500 with respect to the above parameter.

  
Tested by



  
Authorized Signatory

#### Note

- 1 – The results listed above pertain only to the tested samples and applicable parameters.
- 2 – Samples will be stored for a period of 15 days unless otherwise specified.
- 3 – This report is not to be reproduced either wholly or in part and cannot be used as an evidence in the court of law and should not be used in any advertising media without prior written permission.
- 4 – Sampling not done by us unless specified.

# Annexure C

Appendix-XIII

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No. MOH(CMLM) PR/97/2024-25

Dated: 27/06/24

It is certified that an inspection team headed by ..... Medical Officer of Health .....  
(Name of Officers with designation) from ..... Dr. Manohar. N .....  
(Name of Department/ Office) inspected the ..... BBMP (Health) .....  
(Name & Address of the school) on ..... 26/06/24 ..... (date of inspection), checked the water test report submitted by the school and found that the school has potable drinking water for students and staff of the institution and is having provision for running water in the toilets and maintaining hygienic sanitation condition in the school building & the campus as per norms prescribed by the Central/ State/ U.T. Govt.  
The above is valid for a period of ..... One year .....

Signature with Seal: ..... Manohar .....  
27/06/24

Name : ..... ಅರಣ್ಯ ವೈದ್ಯಾಧಿಕಾರಿ .....

Designation : ..... (ಮಲ್ಲೇಶ್ವರಂ) ವಿಭಾಗ .....

ಬೃಹತ್ ಬೆಂಗಳೂರು ಮಹಾನಗರ ಪಾಲಿ

Assistant Engineer of ಬೆಂಗಳೂರು - 03

the Govt. Public Health Department (PHED)/

Authorised officer of the Local Body

Name & Address of the Office / Department : .....

To

HKE Society .....

National Public School .....

15<sup>th</sup> near 9<sup>th</sup> cross, Sadashivanagar  
(Name & Address of the Institution) Bangalore-560080

\* The filled up certificate should be either in Hindi or English. If it is issued in vernacular language, translated notarized version in English be uploaded along with the original vernacular certificate as a single pdf.